

RTG Warehouse Expansion, Dunn, NC

Unit Prices & Alternates from PreBid Meetings (Add#1)

UNIT PRICING

1. Provide a unit price (\$/LF) for 6' high chain link site fencing with barbed wire.
2. Provide a unit price (\$/LF) for 4' high vinyl coated chain link site fencing.
3. **Provide a unit price (\$/CY measured in-place) to undercut and replace unsuitable soils with structural fill.**

ALTERNATES

1. (Division 2) Provide alternate price for steel fiber reinforced concrete pavement in lieu of specified.
2. (Division 3) Provide price for alternate concrete warehouse slab reinforcement in lieu of specified.
3. (Division 3) Provide a maximum 20% substitution of cement with fly-ash meeting ASTM C618, Class F for foundations, tilt wall and concrete pavement.
4. Provide Contractor cost saving/value added suggestions.

ADDITIONAL CLARIFICATIONS

Work includes removal of up to three (3) feet of existing saturated or very soft sediment from the pond.

End